



E & D SPECIALTY STANDS, INC.
MANUFACTURERS OF QUALITY STANDS AND SEATING
2081 FRANKLIN STREET - P.O. BOX 700 - NORTH COLLINS, NEW YORK 14111
716-337-0161 - 1-800-525-8515
FAX 716-337-2903 - SALES FAX 716-337-3436

GENERAL SPECIFICATION ALUMINUM ANGLE FRAME FULL PLANK DECKING

SECTION 13125 – GRANDSTANDS / BLEACHERS

PART 1 - GENERAL

- A. RELATED DOCUMENTS
- B. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.
- I. SUMMARY
 - A. ASTM A572-50 Structural Steel Hot-Dipped Galvanized after fabrication to ASTM A123 Specifications.
 - B. ASTM A307 - Specification for Carbon Steel Bolts and Studs (Ordinary Bolts)
 - C. ASTM A325 - Specification for Carbon Steel Bolts (High Strength Bolt)
 - D. All Bolts and Nuts to have a Hot-Dipped Galvanized Finish.
- 1.3 SUBMITTALS:
 - A. Submit shop drawings in accordance with Section 01300 - Submittals.
 - B. Shop Drawings: Shop Drawings submitted shall be Designed and Detailed under the direct supervision of a licensed in house Professional Engineer. The Professional Engineer shall be present during the time the design and detailing is completed unless all details are included on the approval drawings bearing his/her seal.
- 1.4 QUALITY ASSURANCE:
 - A. Codes and Standards: Design, fabrication, and installation shall be in accordance with BOCA, IBC 2000 Codes and the American's with Disabilities Act for wheelchair accessibility.
 - B. Manufacturer Qualifications: Minimum 10 years experience in the design and manufacture of permanent beam design grandstands.
 - C. Installer Qualifications: Employees to be trained and experienced in the installation of permanent grandstands.
 - D. Welders: AWS certified.
- 1.5 PROJECT/SITE CONDITIONS:
 - A. Owner shall verify site location.
 - B. Owner will locate all underground utilities and obstructions.
 - C. Owner will furnish a geotechnical report indicating soil conditions for proper foundation design.

1.6 WARRANTY:

- A. Grandstands manufactured by E & D Specialty Stands, are warranted for a period of one year against defects in materials and workmanship starting after completion of the project. This does not apply to any damage resulting from neglect, misuse or improper handling of such material by the owner.

PART 2 - PRODUCTS

2.1 MANUFACTURER

- A. E & D Specialty Stands, Inc.
2081 Franklin Street
P.O. Box 700
North Collins, N.Y. 14111
Tel (800) 525-8515, Fax (716) 337-3436

2.2 PERMANENT BEAM DESIGN GRANDSTANDS

- A. Design: The design shall be in accordance with the generally accepted standards as published by The American Institute of Steel Construction and The Aluminum Association.
- B. Design Loads:
 - 1) A uniformly distributed live load of not less than 100 psf of gross horizontal projection of the grandstand.
 - 2) Grandstand shall be designed to withstand, with or without live loads, the horizontal and uplift pressures due to the wind. Wind pressures shall be derived from SEI/ASCE 7-02, Minimum Design Loads in Buildings and Other Structures.
 - 3) A horizontal swaying force applied to the seats, in a direction parallel to the length of the seats, of 24 lbs./ft.
 - 4) A horizontal swaying force applied to the seats, in a direction perpendicular to the length of the seats, of 10 lb./ft.
 - 5) All seat and footboard members shall be designed for live loads of not less than 120 lb. per lineal foot.
 - 6) Guardrails shall be capable of sustaining a vertical load of 100 plf. and a horizontal thrust of 50 plf acting outwardly at the top of the rail.
 - 7) Under these loads, stresses shall not exceed those allowed in the "Specifications for Structural Steel Buildings, June 1, 1989" as adopted by the American Institute of Steel Construction.
- C. Shop Connections: Welded and capable of carrying stress put upon them as per AWS standards.
- D. Supporting Members (Framework):
 - 1) Stringers: Main supporting members are to be of a welded angle frame design, spaced 6'-0" on center. (maximum)
 - 2) Framework: Frames shall be constructed of a minimum of 1 3/4" x 1 3/4" x 3/16"
 - 3) Decking angles: The footboards support angles shall be designed using 2 1/2" x 2" x 3/16" to meet loading requirements and for strength.
 - 4) Cross Bracing: Bracing shall be structural steel angle 1 3/4" x 1 3/4" x 3/16", bolted at ends and centers to the adjacent frame.
- E. Product Description: "Full Plank Deck" (F/P)
The planking system shall be maintenance free, corrosion resistant all aluminum deck. The deck extrusions shall have a minimum actual vertical support rib height

of 1 ¾". The tread surface shall have a non-slip anti-skid fluted design for safety and designed for a concealed fastening system to the understructure.

F. Decking Arrangement: Full Plank Decking Series

- a. Seat boards shall be 2 x 10 flat extruded aluminum alloy, 6063-T6 with clear anodized Class II finish.
- b. The decking system is comprised of various 1 ¾" high aluminum extrusions.
- c. When projected on a horizontal plane, horizontal gaps shall not exceed 0.25 inch between footboards and seatboards.
- d. Where footboards are more than 30 inches above grade, openings between the seat and footboards shall not allow the passage of a sphere greater than 4 inches.
- e. The tread system shall have serrations on the topside for a slip resistant surface.
- f. The riser boards shall be 1 x 6, with the last row having (2) 1 x 6.
- g. All hardware used for attachment of seats, footboards, riser, mid-aisles rails and all other components to be hot-dipped galvanized steel.

G. Dimensions:

- 1) Length of unit: ????
- Number of rows: ??
- 2) Front Walkway: As needed per handicapped compliance and spectator egress.
- 3) Seat Height: 18 inches
- 4) Walkway Elevation: ???
- 5) Aisles: Shall be designed to meet Applicable codes. All aisles shall have a 1" powder coated **black** tread nosing to delineate the leading edge.
- 6) Aisle Rails: Shall be designed of 1 5/8" O.D. anodized aluminum pipe with a height of 36" above the tread nosing and an intermediate rail spaced 12" below the top rail.

H. Typical E & D Stands:

- 1) Standard Design: 8" Rise with a 24" row spacing.
- 2) Front Walkway: Combinations of interlocking tongue and groove planks to achieve the desired code compliant width.

I. Guardrails:

- 1) Furnished on sides of the bleacher including stairs, ramps, vomitories and landings.
- 2) The railing system shall be designed to meet all applicable codes.
- 3) Rails shall be not less than 42" vertically above the center of the seat board surface at the back and sides of the bleacher.
- 4) Rails shall be not less than 42" above the elevated front footrests.
- 5) The railings are to be 1 5/8" O.D. anodized aluminum pipe with end plugs at ends of straight runs and/ or elbows at corners. They are secured to angle railposts with galvanized rail clamps and fasteners.
- 6) Included on all sides of the bleacher will be 2" x 9 Ga. galvanized fencing fastened in place with aluminum ties.

J. Stairs: Shall be provided per applicable codes and/or architects drawings.

- 1) 2 x 12 aluminum plank with a maximum rise of 7", with a 1" contrasting nosing (**black**) to delineate the leading edge.
- 2) Stairs shall have a Multi-pipe Rail system that conforms to the 4" Ball Rule. The top rail shall be 42" above the leading edge of the treads.

- 3) Handrails shall be provided with a 1 ½" clearance from the guardrails and shall extend past the nosing of the last riser with a return.

K. Handicap Provisions:

- 1) All handicapped seating will be in pairs. All handicapped seating to have a companion seat adjacent to them.
- 2) Wheelchair pockets inset into the front rows of seating shall be provided to comply with specified local codes and the "American's with Disabilities Act" for wheelchair accessibility.
- 3) Handicapped seating will be enclosed on all three sides with no exposed vertical rise allowed.
- 4) Front platform shall be accessible from a ramp with a maximum gradient of 1:12.
- 5) Ramp width shall be minimum of 5'-0" for two-way traffic.
- 6) Ramp shall have a rail system to match the grandstand. Top rail will be 42" above the ramp surface.
- 7) A handrail 36" above the ramp surface shall be provided.

2.3 MATERIALS:

- A. Steel: ASTM A572-50 (Hot-Dipped Galvanized)
- B. Aluminum: Extruded alloy 6063-T6
- C. Foundation Concrete: Minimum compression strength of 3000 psi at 28 days.
- D. Accessories:
 - 1) High Strength Bolts and Nuts - ASTM A-325 steel
 - 2) Ordinary Bolts and Nuts - ASTM A-307
 - 3) Hold-Down Clip Assemblies – Aluminum alloy 6063-T6
 - 4) End Caps – Aluminum alloy 6063-T6

2.4 Finishes:

- A. Steel: Shop connections are seal welds. After fabrication, all steel is hot-dipped galvanized to ASTM A123 specifications.
- B. Aluminum:
 - 1) Anodized: Seat planks, risers and pipe shall have a clear anodized 204R1, AA-M10C22A31, Class II.
 - 2) Mill Finish: Footboards

PART 3 - EXECUTION

3.1 Installation

- A. **All work will be performed by factory-trained technicians employed by E & D Specialty Stands with a minimum of 10 years experience in bleacher seating installation. (Using sub-contractors unfamiliar with bleacher erection is prohibited.)**
- B. Complete installation as per approved shop drawings and manufacturers instructions.
- C. After installation, unit shall be inspected for proper alignment and function.

3.2 Foundations/ Concrete Pads

- A. Footings for the grandstand shall be design to provide sufficient bearing area to support the total live and dead loads of the grandstand without exceeding the allowable soil bearing pressure.
- B. Concrete shall attain a working strength of 3,000 psi.
- C. Concrete for slabs shall have 6% +/- 1% air entrainment.
- D. Concrete pad shall have a 6" base of crushed stone.

- E. Concrete pad mesh shall be 3" below the surface of the pad.
- F. Reinforcing steel for a 6" thick slab is 6 x 6, #8/#8 WWF. Minimum splice overlap is 12" Steel fabric size is 6" less than the size in each direction. (3" from edge)